

ZERTIFIKAT

CERTIFICATE

Nr./No. 968/EZ 315.01/09

Prüfgegenstand Product tested	Safety Trip Alarm Device (STA)	Zertifikatsinhaber Holder of the certificate	Moore Industries International, Inc. 16650 Schoenborn Street North Hills, CA 91343-6196 United States of America
Typbezeichnung Type designation	Refer to test report-no.: 968/EZ 315.01/09, section 3.2 for complete type designation	Verwendungszweck Intended application	The Safety Trip Alarm Device is intended to be part of safety related control systems of machines, where the safe state is the de-energized state.
Prüfgrundlagen Codes and standards forming the basis of testing	IEC 61508:1998-2000 EN 62061:2005		
Prüfungsergebnis Test results	The Safety Trip Alarm Device (STA) is suitable for safety related applications up to SIL 2 (IEC 61508).		
Besondere Bedingungen Specific requirements	For the use of the Safety Trip Alarm Device (STA) the installation instruction (released by Moore Industries International Inc.), including recommendations for risk assessment and requirements for maintenance shall be considered.		




Der Prüfbericht-Nr.: 968/EZ 315.01/09 vom 17.04.2009 ist Bestandteil dieses Zertifikates.

Der Inhaber eines für den Prüfgegenstand gültigen Genehmigungs-Ausweises ist berechtigt, die mit dem Prüfgegenstand übereinstimmenden Erzeugnisse mit dem abgebildeten Prüfzeichen zu versehen.

The test report-no.: 968/EZ 315.01/09 dated 2009-04-17 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorised to affix the test mark shown opposite to products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln



2009-04-17

Datum/Date

Firmenstempel/Company stamp

Dipl.-Ing. Heinz Gall